

Appendix I Test results

Table 1.	Heating mode(Low temperature application):						P
Model	CE-iVT9						
Product type	Air to Water	Heating season	<input checked="" type="checkbox"/> Average	<input type="checkbox"/> Warmer	<input type="checkbox"/> Colder		
1. Test conditions:							
Condition	Part Load Ratio in %				Outdoor heat exchanger	Indoor heat exchanger	
	Formula	A	W		Inlet dry (wet) bulb temperature °C	Inlet/outlet water temperatures (°C)	
A	$(-7-16)/(T_{designh-16})$	88	N/A	N/A	-7(-8)	a / 34	
B	$(+2-16)/(T_{designh-16})$	54	N/A	N/A	2(1)	a / 30	
C	$(+7-16)/(T_{designh-16})$	35	N/A	N/A	7(6)	a / 27	
D	$(+12-16)/(T_{designh-16})$	15	N/A	N/A	12(11)	a / 24	
E	$(TOL-16)/(T_{designh-16})$				TOL	a / 35.3	
F	$(T_{bivalent-16})/(T_{designh-16})$				Tbiv	a / 34	
G	$(-15-16)/(T_{designh-16})$	N/A	N/A	N/A	-15	N/A	
Remark: a) With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 30/35 conditions.							
2. Tested data/correction data(Average):							
General test conditions/ Part-Load	Unit	A(-7)/W34 (88%)	A2/W30 (54%)	A7/W27 (35%)	A12/W24 (15%)	A(-10)/W35.3 (100%)	A(-7)/W34 (88%)
	--	A	B	C	D	E	F
Data collection period	hh: min:sec	3:00:00	2:00:00	2:00:00	2:00:00	3:00:00	3:00:00
The heat pump defrosts	--	Yes	No	No	No	Yes	Yes
Complete Cycles	--	1	0	0	0	1	1
Barometric pressure	kPa	101.02	101.02	101.02	101.02	101.02	101.02
Voltage	V	232.8	219.2	232.6	232.7	219.4	232.8
Current input of the unit	A	9.01	4.51	3.30	2.79	9.60	9.01
Power input of the unit	kW	2.057	0.940	0.699	0.576	2.078	2.057
Test conditions indoor unit							
Inlet Water temperature, DB	°C	28.20	26.06	23.14	19.79	29.95	28.20
Outlet Water temperature, DB	°C	33.28*	29.88	26.94	23.97	34.48*	33.28*

Doc No.: ITC-TTW0902.02E – Rev.7

Appendix I Test results

Test conditions outdoor unit							
Air inlet temperature, DB	°C	-6.86	2.00	7.19	12.04	-9.88	-6.86
Air inlet temperature, WB	°C	-7.75	1.00	6.00	11.03	-10.63	-7.75
Summary of the results							
Total heating capacity	kW	5.940	4.470	4.450	4.880	5.276	5.940
Effective power input	kW	2.080	0.963	0.723	0.599	2.102	2.080
Coefficient of performance (COP)	--	2.86	4.64	6.16	8.14	2.51	2.86
Compressor frequency	Hz	75	33	33	33	78	75
Water flow	m³/h	1.00	1.00	1.00	1.00	1.00	1.00
Remark: * In part condition, outlet temperature data is recorded by a full average complete cycle's data.							
3.Calculation/conclusion for SCOP(Average):							
Tdesignh(°C)	-10	Tbiv(°C)		-7			
Pdesignh(kW)	6.714	TOL(°C)		-10			
Test result A, B, C, D, E, F conditions:							
Condition	Part load	Measured capacity	COP at measured capacity	Cdh	CR	COP at part load	
E	6.714	5.276	2.51	0.00	1.00	2.51	
F	5.940	5.940	2.86	0.00	1.00	2.86	
A	5.940	5.940	2.86	0.00	1.00	2.86	
B	3.615	4.470	4.64	0.99	0.81	4.63	
C	2.324	4.450	6.16	0.99	0.52	6.10	
D	1.033	4.880	8.14	0.99	0.21	7.85	
CR: part load divided by capacity;							

Doc No.: ITC-TTW0902.02E – Rev.7

Appendix I Test results

Electric power consumptions	Unit	Value
Thermostat-off mode [P_{TO}]	kW	0.009
Standby mode [P_{SB}]	kW	0.009
Crankcase heater [P_{CK}]	kW	0.033
Off mode [P_{OFF}]	kW	0.009

Conclusions:	Unit	Value
SCOP _{on} :	kWh/kWh	4.69
SCOP:	kWh/kWh	4.68
Q_H :	kWh/year	13872
Q_{HE} :	kWh/year	2966
$\eta_{s,h}$	%	184.1
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 2)	--	A+++

Appendix I Test results

Table 2.	Heating mode(Medium temperature application):						P	
Model	CE-iVT9							
Product type	Air to Water	Heating season	<input checked="" type="checkbox"/> Average	<input type="checkbox"/> Warmer	<input type="checkbox"/> Colder			
1. Test conditions:								
Condition	Part Load Ratio in %				Outdoor heat exchanger	Indoor heat exchanger		
	Formula	A	W	C	Inlet dry (wet) bulb temperature °C	Inlet/outlet water temperatures (°C)		
A	$(-7-16)/(T_{designh-16})$	88	N/A	N/A	-7(-8)	a / 52		
B	$(+2-16)/(T_{designh-16})$	54	N/A	N/A	2(1)	a / 42		
C	$(+7-16)/(T_{designh-16})$	35	N/A	N/A	7(6)	a / 36		
D	$(+12-16)/(T_{designh-16})$	15	N/A	N/A	12(11)	a / 30		
E	$(TOL-16)/(T_{designh-16})$				TOL	a / 55.3		
F	$(T_{bivalent-16})/(T_{designh-16})$				Tbiv	a / 52		
G	$(-15-16)/(T_{designh-16})$	N/A	N/A	N/A	-15	N/A		
Remark: a) With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 47/55 conditions.								
2. Tested data/correction data(Average):								
General test conditions/ Part-Load	Unit	A(-7)/W52 (88%)	A2/W42 (54%)	A7/W36 (35%)	A12/W30 (15%)	A(-10)/W55.3 (100%)	A(-7)/W52 (88%)	
	--	A	B	C	D	E	F	
Data collection period	hh: min:sec	2:00:00	2:00:00	2:00:00	2:00:00	4:00:00	2:00:00	
The heat pump defrosts	--	No	No	No	No	Yes	No	
Complete Cycles	--	0	0	0	0	1	0	
Barometric pressure	kPa	101.02	101.02	101.02	101.02	101.02	101.02	
Voltage	V	230.0	230.8	233.2	231.2	230.5	230.0	
Current input of the unit	A	12.69	4.79	4.07	3.33	12.40	12.69	
Power input of the unit	kW	2.890	1.052	0.891	0.709	2.825	2.890	
Test conditions indoor unit								
Inlet Water temperature, DB	°C	45.57	38.36	31.89	25.33	48.54	45.57	
Outlet Water temperature, DB	°C	52.08	41.95	36.00	30.00	54.03*	52.08	

Doc No.: ITC-TTW0902.02E – Rev.7

Appendix I Test results

Test conditions outdoor unit							
Air inlet temperature, DB	°C	-6.99	2.01	7.00	12.05	-9.97	-6.99
Air inlet temperature, WB	°C	-7.64	1.00	6.00	11.00	-10.96	-7.64
Summary of the results							
Total heating capacity	kW	6.300	3.513	4.073	4.607	5.118	6.300
Effective power input	kW	2.909	1.070	0.909	0.727	2.843	2.909
Coefficient of performance (COP)	--	2.17	3.28	4.48	6.34	1.80	2.17
Compressor frequency	Hz	78	33	33	33	78	78
Water flow	m³/h	0.85	0.85	0.85	0.85	0.85	0.85
Remark: * In part condition, outlet temperature data is recorded by a full average complete cycle's data.							
3.Calculation/conclusion for SCOP(Average):							
Tdesignh(°C)	-10	Tbiv(°C)		-7			
Pdesignh(kW)	7.122	TOL(°C)		-10			
Test result A, B, C, D, E, F conditions:							
Condition	Part load	Measured capacity	COP at measured capacity	Cdh	CR	COP at part load	
E	7.122	5.118	1.80	0.00	1.00	1.80	
F	6.300	6.300	2.17	0.00	1.00	2.17	
A	6.300	6.300	2.17	0.00	1.00	2.17	
B	3.835	3.513	3.28	0.00	1.00	3.28	
C	2.465	4.073	4.48	0.99	0.61	4.45	
D	1.096	4.607	6.34	0.99	0.24	6.14	
CR: part load divided by capacity;							





Doc No.: ITC-TTW0902.02E – Rev.7

Appendix I Test results

Electric power consumptions	Unit	Value
Thermostat-off mode [P_{TO}]	kW	0.009
Standby mode [P_{SB}]	kW	0.009
Crankcase heater [P_{CK}]	kW	0.038
Off mode [P_{OFF}]	kW	0.009

Conclusions:	Unit	Value
SCOP _{on} :	kWh/kWh	3.25
SCOP:	kWh/kWh	3.24
Q_H :	kWh/year	14713
Q_{HE} :	kWh/year	4542
$\eta_{s,h}$	%	126.6
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 1)	--	A++

Appendix II Marking plate

Nameplate	
Model: <u>CE-iVT9</u>	
 	
Air Source Heat Pump	
Model	CE-iVT9
Heating Capacity Min./Max. (A7)	4.37/9.5kW
Heating Input Power Min./Max.	0.79/2.14kW
Cooling Capacity Min./Max.	3.08/6.7kW
Cooling Input Power Min./Max.	0.85/2.67kW
Power Supply	220V-240V/50Hz
Shock Proof Grade	I
Ingress Protection	IPX4
Rated Input Current	6.2A
Max. Input Current	14.8A
Max. Water Outlet Temperature	55°C
Minimum Water Flow Rate	1m ³ /h
Refrigerant /Weight	R410A/1600g
Water Pressure Drop	20kPa
Water Pipe Connection	1" BSP
Max Water Pressure	1.0MPa
Net Weight	88kg
Product Barcode Right:	 0 703694 534645
Serial - See Sticker Below:	
Cool Energy Holding Ltd 163 Cleethorpe Road, Grimsby DN31 3AX, North East Lincolnshire, UK www.coolenergyshop.com	
	

Doc No.: ITC-TTW0902.02E – Rev.7