



Notes:

Heat pump to be wall mounted at the bin area of the property.

The heat pump will require local electrical isolation. 25amp supplied by customer

The heat pump will require a gully or purpose made soak away for condensate removal, supplied by customer.

EcoDan spec
 Width 1020mm
 Height 1050mm
 Depth 360mm

Cylinder spec
 Width 540mm
 Height 1490mm
 Heat loss kWh/24hr 1.67
 Reheat time 65.81 min
 Weight full 277 kg

Plumbing
 x2 28mm pipes from the outdoor unit location to the cylinder cupboard
 D2 pipe from the cylinder to a drain
 Heating flow/return to cylinder location
 hot/cold supply to cylinder location 22mm

Electrical
 Supply to the outdoor unit 25 amp to outdoor unit. This will require metering for RHI payments
 Supply to immersion heater 16amp
 1.5mm x 3 core and earth from the outdoor unit to the cylinder location at indoor unit.